

13. Lighting in retail display windows, provided the display area is enclosed by ceiling-height partitions.
14. Furniture mounted supplemental task lighting that is controlled by automatic shutoff.

**C405.5.1.1 Screw lamp holders.** The wattage shall be the maximum *labeled* wattage of the luminaire.

**C405.5.1.2 Low-voltage lighting.** The wattage shall be the specified wattage of the transformer supplying the system.

**C405.5.1.3 Other luminaires.** The wattage of all other lighting equipment shall be the wattage of the lighting equipment verified through data furnished by the manufacturer or other *approved* sources.

**C405.5.1.4 Line-voltage lighting track and plug-in busway.** The wattage shall be:

1. The specified wattage of the luminaires included in the system with a minimum of 30 W/lin ft. (98 W/lin. m);
2. The wattage limit of the system’s circuit breaker; or
3. The wattage limit of other permanent current limiting device(s) on the system.

**C405.5.2 Interior lighting power.** The total interior lighting power allowance (watts) is determined according to Table C405.5.2(1) using the Building Area Method, or Table C405.5.2(2) using the Space-by-Space Method, for all areas of the building covered in this permit. For the Building Area Method, the interior lighting power allowance is the floor area for each building area type listed in Table C405.5.2(1) times the value from Table C405.5.2(1) for that area. For the purposes of this method, an “area” shall be defined as all contiguous spaces that accommodate or are associated with a single building area type as listed in Table C405.5.2(1). Where this method is used to calculate the total interior lighting power for an entire building, each building area type shall be treated as a separate area. For the Space-by-Space Method, the interior lighting power allowance is determined by multiplying the floor area of each space times the value for the space type in Table C405.5.2(2) that most closely represents the proposed use of the space, and then summing the lighting power allowances for all spaces. Tradeoffs among spaces are permitted.

**C405.6 Exterior lighting (Mandatory).** Where the power for exterior lighting is supplied through the energy service to the building, all exterior lighting, other than low-voltage landscape lighting, shall comply with Sections C405.6.1 and C405.6.2.

**Exception:** Where *approved* because of historical, safety, signage or emergency considerations.

**C405.6.1 Exterior building grounds lighting.** All exterior building grounds luminaires that operate at greater than 100 watts shall contain lamps having a minimum efficacy of 60 lumens per watt unless the luminaire is controlled by a motion sensor or qualifies for one of the exceptions under Section C405.6.2.

**TABLE C405.5.2(1)  
INTERIOR LIGHTING POWER ALLOWANCES:  
BUILDING AREA METHOD**

BUILDING AREA TYPE	LPD (w/ft²)
Automotive facility	0.9
Convention center	1.2
Courthouse	1.2
Dining: bar lounge/leisure	1.3
Dining: cafeteria/fast food	1.4
Dining: family	1.6
Dormitory	1.0
Exercise center	1.0
Fire station	0.8
Gymnasium	1.1
Health care clinic	1.0
Hospital	1.2
Hotel	1.0
Library	1.3
Manufacturing facility	1.3
Motel	1.0
Motion picture theater	1.2
Multifamily	0.7
Museum	1.1
Office	0.9
Parking garage	0.3
Penitentiary	1.0
Performing arts theater	1.6
Police station	1.0
Post office	1.1
Religious building	1.3
Retail	1.4
School/university	1.2
Sports arena	1.1
Town hall	1.1
Transportation	1.0
Warehouse	0.6
Workshop	1.4